



കേരള ഗസറ്റ് KERALA GAZETTE

അസാധാരണം EXTRAORDINARY

ആധികാരികമായി പ്രസിദ്ധപ്പെടുത്തുന്നത്
PUBLISHED BY AUTHORITY

വാല്യം 12
Vol. XII

തിരുവനന്തപുരം,
തിങ്കൾ

Thiruvananthapuram,
Monday

2023 ജൂലൈ 10
10th July 2023

1198 മിഥുനം 25
25th Mithunam 1198

1945 ആഷാഢം 19
19th Ashadha 1945

നമ്പർ
No.

2278

GOVERNMENT OF KERALA

Power (A) Department

NOTIFICATION

G. O. (P) No. 3/2023/Power.

Dated, Thiruvananthapuram, 17th June, 2023.

S. R. O. No. 759/2023

In exercise of the powers conferred by sub-section (1) of section 162 of the Electricity Act, 2003 (Central Act 36 of 2003) read with regulation 32 of the Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2010, the Government of Kerala hereby make the following amendment to the notification issued under G. O. (P) No. 1/2017/P.D. dated 28th January, 2017 and published as S.R.O. No. 77/2017 in the Kerala Gazette Extraordinary No. 270 dated 14th February, 2017, namely:—



AMENDMENT

In the said notification,—

in paragraph 1, under the heading “*Inspection and testing of generating units*”, after the words and symbols “(hereinafter referred to as the said Regulations).”, the following sentence shall be added, namely:—

“In the case of generating units producing electricity from solar source of energy having capacity above 50kWp shall be inspected by the Electrical Inspector or any officer appointed to assist the Electrical Inspector before commissioning.”

By order of the Governor,

K. R. JYOTHILAL,
Additional Chief Secretary.

Explanatory Note

(This does not form part of the notification, but is intended to indicate its general purport.)

Government had issued notification under G.O.(P) No. 1/2017/P.D. dated 28th January, 2017 and published as S.R.O. No. 77/2017 in the Kerala Gazette Extraordinary No. 270 dated 14th February, 2017 regarding the supply voltage, capacity and connected load of the electrical installations and the interval of the periodical inspection by the Electrical Inspectors.

As part of the compliance burden reduction exercise in accordance with Ease of doing Business, the Chief Electrical Inspector has submitted a proposal to promote Solar Source of Energy Projects to Government. Government have examined the matter in detail and decided to make suitable amendment in the above notification.

The notification is intended to achieve the above object.

